IEC IECEE CB SCHEME	Ref. Certif. No.
	CN50749

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Pilot device
Name and address of the applicant	ABB Xinhui Low Voltage Switchgear Co.,Ltd. Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China
Name and address of the manufacturer	ABB Xinhui Low Voltage Switchgear Co.,Ltd. Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China
Name and address of the factory *Note: When more than one factory, please report on page 2*	ABB Xinhui Low Voltage Switchgear Co.,Ltd. Jinguzhou Industrial Development Zone, Xinhui District, Jiangmen City, Guangdong Province, P.R.China
Ratings and principal characteristics	See the Appendix
Trademark (if any)	ABB
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	TYPE C(CP、C2SS、C3SS、CL、CE、CB、CEP);
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-5-1:2016(4th Edition)
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2020CQC-091188

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn

Date: Jul.19,2020

Signature: Lu Mei

CB 0056958

TYPE C(CP、C2SS、C3SS、CL、CE、CB、CEP);
Ui:300V（Pushbutton、Selector Switch、Emergency Stop，Buzzer and Illuminated Pushbutton），415V（Pilot Light）；
Uimp:6kV（Pushbutton、Selector Switch、Emergency Stop and Illuminated Pushbutton），4kV（Buzzer）；
Ith:5A(Pushbutton、Selector Switch、Emergency Stop and Illuminated Pushbutton);
Pushbutton、Selector Switch、Emergency Stop and Illuminated Pushbutton、Enclosure and Enclosure Station
AC-15: 120V/3A, 240V/2A（Contact：Ag），120V/1.5A, 240V/1A（Contact：Cu/Ep.Ag）; DC-13: 24V/0.3A, 125V/0.2A;
LED: Ue=110-130VAC, 230VAC, Ie=15mA;
Ue=48VAC/DC,Ie=12mA;Ue=110-130VDC,Ie=7mA; Ue=220VDC, Ie=5mA;
Ue=380VAC,Ie=16mA;Ue=60VAC/DC,415VAC,Ie=17mA;
LED II: Ue=48-60VAC/DC，Ie=13-17mA;
Ue=110-130VAC，Ie=15-17mA；Ue=110-130VDC，Ie=8-9mA；Ue=230VAC，Ie=17mA;
Ue=220VDC，Ie=6mA；Ie=2mA(CL2-720), Ue=380-415VAC，Ie= 15-17mA;
LED with white weave：Uemax=240VAC;
Buzzer (red with lamp, yellow with lamp):
Ue=110-130VAC,230VAC, Ie=70mA;Ue=110-130VDC,Ie=15mA;
(green with lamp):Ue=110-130VAC,230VAC,Ie=55mA; Ue=110-130VDC, Ie=15mA;
Degree of protection:
Terminal: IP20
CL9:
Lens with gasket: IP66 when product is assembled on the specific panel
Lens without gasket: IP40 when product is assembled on the specific panel
CEP:
Handles without shroud or legend plate: IP66

Handles with shroud or legend plate: IP40

Additional information (if necessary)

Date: Jul.19,2020

Signature: Lu Mei

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666
Fax: +86-10-83886282
website
http://www.cqc.com.cn