PERFORMANCE MADE SMARTER



2-wire programmable transmitter

5331D


- RTD, TC, Ohm, or mV input
- Extremely high measurement accuracy
- 1.5 kVAC galvanic isolation
- Programmable sensor error value
- For DIN form B sensor head mounting

Application
- Linearized temperature measurement with Pt100...Pt1000, Ni100...Ni1000, or TC sensor.
- Conversion of linear resistance variation to a standard analog current signal, for instance from valves or Ohmic level sensors.
- Amplification of a bipolar mV signal to a standard 4...20 mA current signal.

Technical characteristics
- Within a few seconds the user can program PR5331D to measure temperatures within all ranges defined by the norms.
- The RTD and resistance inputs have cable compensation for 2-, 3- and 4-wire connection.
- Continuous check of vital stored data for safety reasons.

Mounting / installation
- For DIN form B sensor head mounting.

Applications



This page is automatically generated on the basis of information provided on www.prelectronics.com and affiliated websites. It is provided to you as a service and for information purpose only. While we have attempted to maintain the information as accurately as possible, the page may contain errors or omissions for which we disclaim any and all liability

Order:

Type	Ambient temperature	Galvanic isolation
5331D	-40°C...+85°C : 3	1500 VAC : B

Environmental Conditions

Operating temperature..... -40°C to +85°C
Calibration temperature..... 20...28°C
Relative humidity..... < 95% RH (non-cond.)
Protection degree (encl./terminal)..... IP68 / IP00

Mechanical specifications

Dimensions..... Ø 44 x 20.2 mm
Weight approx..... 50 g
Wire size..... 1 x 1.5 mm^2 stranded wire
Screw terminal torque..... 0.4 Nm
Vibration..... IEC 60068-2-6
2...25 Hz..... ±1.6 mm
25...100 Hz..... ±4 g

Common specifications

Supply
Supply voltage..... 7.2...30 VDC
Internal power dissipation..... 25 mW…0.7 W

Isolation voltage
Isolation voltage, test / working..... 1.5 kVAC / 50 VAC

Response time
Response time (programmable)..... 1...60 s

Voltage drop..... 7.2 VDC
Warm-up time..... 5 min.
Programming..... Loop Link
Signal / noise ratio..... Min. 60 dB
EEprom error check..... < 3.5 s
Accuracy..... Better than 0.05% of selected range
Signal dynamics, input..... 20 bit
Signal dynamics, output..... 16 bit
Effect of supply voltage change..... < 0.005% of span / VDC
EMC immunity influence..... < ±0.5% of span
Extended EMC immunity: NAMUR NE21, A criterion, burst..... < ±1% of span

Input specifications

Common input specifications
Max. offset..... 50% of selected max. value

RTD input
RTD type..... Pt100, Ni100, lin. R
Cable resistance per wire..... 5 Ω (max.)
Sensor current..... Nom. 0.2 mA
Effect of sensor cable resistance (3-/4-wire)..... < 0.002 Ω / Ω
Sensor error detection..... Yes

Linear resistance input
Linear resistance min....max..... 0 Ω...5000 Ω

TC input
Thermocouple type..... B, E, J, K, L, N, R, S, T, U, W3, W5, LR
Cold junction compensation (CJC)..... < ±1.0°C
Sensor error detection..... Yes
Sensor error current: When detecting / else..... Nom. 33 µA / 0 µA

Voltage input
Measurement range..... -12...800 mV
Min. measurement range (span)..... 5 mV
Input resistance..... 10 MΩ

Output specifications

Current output
Signal range..... 4…20 mA
Min. signal range..... 16 mA
Load (@ current output)..... ≤ (Vsupply - 7.2) / 0.023 [Ω]
Load stability..... ≤ 0.01% of span / 100 Ω
Sensor error indication..... Programmable 3.5…23 mA
NAMUR NE43 Upscale/Downscale..... 23 mA / 3.5 mA

Common output specifications
Updating time..... 440 ms

of span..... = of the presently selected range

I.S. / Ex marking

ATEX..... II 1 G Ex ia IIC T4...T6 Ga, II 1 D Ex ia IIIC Da, I M1 Ex ia Ma
IECEx..... Ex ia IIC T4...T6 Ga, Ex ia IIIC Da, Ex ia I Ma
FM, US..... Cl. I, Div. 1, Gp. A, B, C, D T4/T6; Cl. I Zone 0, AEx ia IIC T4/T6; Cl. 1, Div. 2, Gp. A, B, C, D, T4/T6
CSA..... Cl. I, Div. 1, Gp. A, B, C, D Ex ia IIC, Ga
INMETRO..... Ex ia IIC T6...T4 Ga, Ex ia IIIC Da

Observed authority requirements

EMC..... 2014/30/EU
RoHS..... 2011/65/EU
EAC..... TR-CU 020/2011

Approvals

DNV-GL Marine..... Stand. f. Certific. No. 2.4
ATEX 2014/34/EU..... KEMA 06ATEX0062X
IECEx..... DEK 13.0035X
FM..... FM17US0013X
CSA..... 1125003
INMETRO..... DEKRA 16.0013 X
EAC Ex TR-CU 012/2011..... RU C-DK.GB08.V.00410