MOFLASH SIGNALLING
BIRMINGHAM, ENGLAND

E1EX

Ex db IIC, Ex eb IIC, Ex ta IIIC, Ex nR IIC CAPTIVE COMPONENT GLAND®

WITH VARIABLE DELUGE SEAL™ for Steel and Aluminium Armoured Cable



Features and Benefits

- For indoors, outdoors, Group II, III, Zone 1, 2, 20, 21 and 22 hazardous areas.
- Two-part handling, no loose parts.
- A freely rotating captive cone and inspectible cone ring provide an armour clamp and earth bond on steel wire and aluminium armour.
- A patented disconnect system allows for inspection of the armour clamp and inner seal after assembly.
- With a patented Variable Deluge Seal™ as standard.
- Factory fitted with a specially formulated elastomeric seal for Built-in Safety™, seals on the inner and outer sheath of the cable to IP65/66/68.
- Precision manufactured from high-quality brass (Marine Grade Electroless Nickel Plated™) available in aluminium or stainless steel 316/316L on request.
- Supplied with a thread-sealing gasket (parallel threads only).

Technical Data

Type:	E1EX
Gland Material:	Brass (Marine Grade Electroless Nickel Plated™), Aluminium, Stainless Steel 316/316L
Seal Material:	Standard Thermoset Elastomer or Extreme Temperature Seals
Sealing Gasket Material:	HDPE, Nylon 66 or PTFE
Cable Type:	Steel Wire Armour and Aluminium Armour
Armour Clamping:	Rotating Captive Cone and Inspectible Cone Ring
Sealing Area:	Inner Sheath, Outer Sheath and Variable Deluge Seal™
Optional Accessories:	Adaptor, Reducer, Earth Tag, Locknut, Serrated Washer and Shroud
Note:	The installer should ensure that the materials are suitable for the installation environment.

Standards and Certifications

Equipment Protection Levels:	IECEx/INMETRO: Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc, Ex ta IIIC Da ATEX/UKEX: II 2/3 G 1D, Ex db IIC Gb, Ex eb IIC Gb, Ex nR IIC Gc Ex ta IIIC Da CCC: Ex db IIC Gb, Ex eb IIC Gb, Ex ta IIIC Da	
Continuous Operating Temp:	Standard Seals: -60°C to +95°C/100°C (HDPE/ Nylon Sealing Gasket) Extreme Temp. Seals: -60°C to +160°C (PTFE Sealing Gasket)	
Conformance:	Standard:	Certificate:
IEC/BS EN	IEC/BS EN 62444, 6121	CML 14CA364
IECEx	IEC 60079 Part 0, 1, 7, 15, 31	IECEx CML 18.0018X
ATEX	EN 60079 Part 0, 1, 7, 31 EN 60079 Part 0, 15	CML 16ATEX1001X CML 16ATEX4002X
UKEX	BS EN 60079 Part 0, 1, 7, 31 BS EN 60079 Part 0, 15	CML 21UKEX1011X CML 21UKEX4006X
INMETRO (Brazil)	ABNT NBR IEC 60079 Part 0, 1, 7, 15, 31	TÜV 24.0267
CCC/CNEx (Chinese)	GB/T3836.1, 2, 3, 31-2021	CNEx 21.3387X CCC 2021312313000396
SANS	SANS/IEC 60079 Part 0, 1, 7, 15, 31	MASC MS/22-9001X
IP66/68 100m - Parallel	IEC 60529	CML 15Y728
IP65/66 - Tapered	IEC 60529	
IP68 - Tapered and approved grease	IEC 60529	IECEx CML 18.0018X
Deluge Protection	DTS-01	CML 14CA370-2
Corrosion Protection	ASTM B117-11, BS EN ISO 3231	EXOVA N968667
Marine ABS	IEC 60079 Part 0, 1, 7, 15, 31 and IEC 60529	25-0164964-PDA
DNV	IEC 60079 Part 0, 1, 7, IEC 60529	TAE0000010
EMC Compatible	EN 55011, + A1, EN 55022	SGS EMC305079/1



PATENTED

Conditions for Safe Use - X

- The cable glands shall only be used where the temperature, at the point of entry, is between -60°C to +95°C (standard seals & HDPE sealing gaskets), -60°C to +100°C (standard seal and Nylon sealing gasket) or -60°C to +160°C (extreme temp. seal & PTFE sealing gasket) depending on seal and gasket used.

Note: According to IEC 60079-14, 10.6.2: An Ex d gland will only maintain Ex d integrity when used with substantially round, compact and filled cable. If not a CCG VORTEx® barrier gland should be used.

MOFLASH Product Code	Material	Gland Size Ref	Metric Entry Thread		Cable Detail				Max Length 'E'	Armour Dia		Hexagonal Detail		Install. Torque Value Nm
			'C'	Min 'D'	Min 'A'	Max 'A'	Min 'B'	Max 'B'		Min 'F'	Max 'F'	Max 'Flats'	Max 'Crns'	
50250	Brass	00-20ss	M20x1.5	15	3.0	8.5	8.0	13.5	60.0	0.90	0.90	24.0	27.0	21.0
50251	Brass	0-20s	M20x1.5	15	7.0	12.0	11.5	16.0	60.0	0.90	1.25	24.0	27.0	21.0
50200	Brass	1-20	M20x1.5	25	9.0	15.0	14.5	20.5	63.0	0.90	1.25	27.0	30.0	21.0
50252	Brass	2-25	M25x1.5	15	14.0	20.0	20.5	26.5	70.0	1.25	1.60	35.0	39.0	30.0
50253	Stainless Steel	00-20ss	M20x1.5	15	3.0	8.5	8.0	13.5	60.0	0.90	0.90	24.0	27.0	21.0
50254	Stainless Steel	0-20s	M20x1.5	15	7.0	12.0	11.5	16.0	60.0	0.90	1.25	24.0	27.0	21.0
50210	Stainless Steel	1-20	M20x1.5	15	9.0	15.0	14.5	20.5	63.0	0.90	1.25	27.0	30.0	21.0

All dimensions are in mm. Intermediate thread sizes are available on request.

CCG reserves the right to make alterations to the technical data, dimensions, designs and products available without notice. The illustrations cannot be considered binding. Please contact Moflash for assistance.

2026 © CCG CABLE TERMINATIONS (PTY) LTD

FITTING INSTRUCTIONS
Metric Illustration

MOFLASH SIGNALLING
BIRMINGHAM, ENGLAND

E1EX GLAND

ENCLOSURES AND EQUIPMENT TO WHICH CABLE GLANDS ARE FITTED:-
- Must be made from materials which are compatible with the cable gland materials.
- Have a sealing area around the cable gland entry point with a surface roughness < Ra 6.3 µm.
- Have entries that are perpendicular to the enclosure face in the area where the cable gland will seal to within 2.5°.
- Are sealed using the supplied sealing gasket (parallel threads) or by fully tightening into a threaded entry (tapered threads). Note that for tapered threads the IP rating can be improved to IP68 with the use of a suitable thread sealant.

MUST HAVE THREADED ENTRIES
- The same thread size as the cable gland. (Thread adapters should be used to correct any mismatch).
- With a thread tolerance of metric class '6H' or equivalent.
- Where the thread length is a minimum of 10mm for Ex d applications or 3mm for all other applications

OR CLEARANCE HOLES (not Ex d)
- Where the hole size is the thread nominal size with a tolerance of +0.1 to +0.7mm. (e.g. the clearance hole for an M20 thread will have a diameter between 20.1mm and 20.7mm).
- Through material that is between 1mm and 12mm thick. (Thicker materials can be accommodated using glands with extended entry threads.)



1. For accurate sizing, use a CCG Dimension Tape Ⓐ on the inner and outer cable sheath.



Gland Size	Armour Length	Gland Size	Armour Length	Gland Size	Armour Length	Gland Size	Armour Length
00-16ss	20	3s-32s	30	6s-63s	45	9-90	50
00-20ss	20	3-32	30	6-63	45	10-100	60
0-20s	20	4s-40s	30	7s-75s	50	11-115	60
1-20	25	4-40	30	7-75	50	12-120	60
2s-25s	25	5s-50s	35	8-80	50	13-130	60
2-25	25	5-50	35	9s-90s	50		

2. Cut back the cable outer sheath to expose the armour to a length as per the table above.



3. To maintain IP66/68, ensure the gasket ① is in place. Screw the inner ② into the apparatus. Tighten the inner ② to the installation torque using a CCG Spanner ⑦.

Alternative installation through an unthreaded entry.

If the apparatus is untapped use a locknut.



If the gland has NPT entry threads fitted to a threaded entry then IP68 (2m) can be achieved by applying one of the following tested and approved grease types to the thread:- Renolit Lubrene CA700 or LX220 EP2, Renolit LC-WP2 or Moly LX2, or Dow Corning 4 Electrical Compound.



4. Pass the outer nut ④ and the body ③ over the cable.



5. Pass the cable end through the inner ②. Splay the armour wires over the cone ⑤.



6. Tighten the body ③ onto the inner ② until hand tight, then tighten with a CCG Spanner ⑦ with ¾ turn to lock the armour between the cone ⑤ and the cone ring ⑥.



7. Unscrew the body ③. Check that the armour has locked between the cone ⑤ and cone ring ⑥. (O-Ring on the cone ⑤ and cone ring ⑥ are sacrificial).



8. Tighten the body ③ onto the inner ② to the installation torque using a CCG Spanner ⑦. The Variable Deluge Seal™ will engage automatically as the body is tightened onto the inner ②. Tighten the outer nut ④ to produce a moisture proof seal by turning until the seal makes contact with the outer sheath of cable and then make one full turn.

YouTube Instruction Video: http://youtu.be/Lw-LxOyyoV0

11 Upper Conybere St, Birmingham B12 0EB, United Kingdom Tel: +44 (0) 121 446 5322 / +44 121 440 5894 , email: uksales@moflash.co.uk