Date: 12/04/2023

PCA2MB 0,8 … 6 bar Adaptor G 1/4 A-M , 1/2 -14 NPT-F

Compact pressure switch, flameproof Enclosure Ex d

Item number: 48792199

Quantity: 1 pcs.

Order code: PCA2MB-BADC-5ASZZZ11Z CZKW
B000500IZZZZZZZZ
F4-C5- - - - -
CERT31-EN2C-FC- - - - - UZZ

Overview:
PCA2MB 0,8 … 6 bar Adaptor G 1/4 A-M , 1/2 -14 NPT-F
Compact pressure switch, flameproof Enclosure Ex d PCA
switch enclosure: aluminium,copper-free
Measuring elements and wetted parts: Diaphragm Inconel + O-Ring FPM
Connection: Stainless steel AISI 316L
contact version: 1xSPDT, silver contact, hermetically sealed with argon gas
0,8 … 6 bar, working range -1 … 10 bar, proof pressure 40 bar
Process connection: Adaptor G 1/4 A-M
Electrical connection: 1/2 -14 NPT-F
standard direct or wall mounting, fixing bore on the case
Ingress Protection: IP66
Brand: WIKA Instruments Italia
Specifications according to data sheet: PV 33.31
Repeatability of set point: ≤ 1% of end of setting range

1. set point: 5.00 bar increasing,

Approvals / Certificates
IECEx-ATEX Ex d
Inspection certificate acc. to EN 10204 3.1
Certificate Language: English
Inspection: 100% Inspection (with calibration values listed each instrument)

Details:
Compact pressure switch, flameproof Enclosure Ex d
Model PCA
Specifications according to data sheet: PV 33.31
Repeatability of set point: ≤ 1% of end of setting range
switch enclosure: aluminium,copper-free
Measuring elements and wetted parts: Diaphragm Inconel + O-Ring FPM
1xSPDT, silver contact, hermetically sealed with argon gas
0,8 … 6 bar, working range -1 … 10 bar, proof pressure 40 bar
Process connection: Adaptor G 1/4 A-M
Electrical connection: 1/2 -14 NPT-F
standard direct or wall mounting, fixing bore on the case
Approvals / Certificates: with

© 2023 - WIKA Instruments s.a.r.l.

Certificates: quality certificates
Brand: WIKA Instruments Italia
Ingress Protection: IP66
PCA2MB 0,8 … 6 bar
1. set point: 5.00 bar increasing,

Approvals / Certificates
IECEx-ATEX Ex d
Inspection certificate acc. to EN 10204 3.1
Certificate Language: English
Inspection: 100% Inspection (with calibration values listed each instrument)

© 2023 - WIKA Instruments s.a.r.l.