Date: 22/04/2024

PCS2MA 0,8 … 6 bar Adaptor G 1/2 A-M, 1/2 -14 NPT-F

Compact Pressure Switch

Item number: 48804329

Quantity: 1 pcs.

Order code: PCS2MA-BADC-4ASZZZZ1Z ZCKW
B000350IZZZZZZZZZ
CERT31-EN2C-FC- - - - - UZZ

Overview:
PCS2MA 0,8 … 6 bar Adaptor G 1/2 A-M, 1/2 -14 NPT-F
Compact Pressure Switch
PCS
switch enclosure: aluminium,copper-free
Measuring elements and wetted parts: Diaphragm Inconel + O-Ring FPM
Connection: Stainless steel AISI 316L
contact version: 1xSPDT, silver contact
Setting range, working range, proof pressure: 0,8 … 6 bar, working range -1 … 10 bar, proof pressure 40 bar
Process connection: Adaptor G 1/2 A-M
Electrical connection: 1/2 -14 NPT-F
standard direct or wall mounting, fixing bore on the case

Ingress Protection: IP66
Brand: WIKA Instruments Italia
Specifications according to data sheet: PV 33.30
Repeatability of set point: ≤ 1% of end of setting range

1. set point: 3.50 bar increasing,

Inspection certificate acc. to EN 10204 3.1
Certificate Language: English
Inspection: 100% Inspection (with calibration values listed each instrument)

Details:
Compact Pressure Switch
Model PCS
Specifications according to data sheet: PV 33.30
Repeatability of set point: ≤ 1% of end of setting range
switch enclosure: aluminium,copper-free
Measuring elements and wetted parts: Diaphragm Inconel + O-Ring FPM
1xSPDT, silver contact
0,8 … 6 bar, working range -1 … 10 bar, proof pressure 40 bar
Process connection: Adaptor G 1/2 A-M
Electrical connection: 1/2 -14 NPT-F
standard direct or wall mounting, fixing bore on the case
Approvals / Certificates: without

© 2024 - WIKA Instruments s.a.r.l.

Switch standard: without
Certificates: quality certificates
Brand: WIKA Instruments Italia
Ingress Protection: IP66
PCS2MA 0,8 … 6 bar
1. set point: 3.50 bar increasing,

Inspection certificate acc. to EN 10204 3.1
Certificate Language: English
Inspection: 100% Inspection (with calibration values listed each instrument)

© 2024 - WIKA Instruments s.a.r.l.