Date: 11/04/2023

SA-11; -1 ... +5 bar; 4...20 mA, 2-W

Pressure transmitter for sanitary applications

Item number: 48711795

Quantity: 1 pcs.

Order code: SA-11-A-BCK-RT-AGA4ZZ-1ZZ W101Z-F2A-GSSAK6
CERT22-EG1P-AA- - - - - - - - - - - SA
CERT31-EG1P-AB-BA- - - - - - - - - - SA
LABEL-PG1GB-ZZZZZ- ZZZZZ

Overview:
SA-11; -1 ... +5 bar; 4...20 mA, 2-W
@ 10 ... 30 V DC; Accuracy: 0.5% of span
Tri-Clamp DN 1 1/2";
4-pin L-plug DIN EN 175301-803, IP65 UB=1, 0V=2
Specifications according to data sheet: PE 81.80
System fill fluid: KN 77 Synthetic oil
Test report 2.2 per EN 10204
Certificate Language: English and German
Certificate for: pressure transmitter
Formal certificate: Manufactured according to state-of-the-art
Inspection certificate 3.1 per EN 10204
Certificate type: Inspection certificate acc. to DIN EN 10204 3.1
Certificate Language: English and German
Certificate for: pressure transmitter
Accuracy: Calibration values listed
Material certificate: Wetted parts material (metal contents)

Label: WIKA standard without / with Tag-number
language of the label: English

Details:
Pressure transmitter for sanitary applications
Model SA-11
Specifications according to data sheet: PE 81.80
Wetted parts: stainless steel 1.4435
Case: stainless steel
Permissible medium temperature: -20 ... +150 °C (-4 ... +302 °F)
Output signal: 4 ... 20 mA, 2-wire
Unit: bar
Measuring range: -1 ... +5 bar
Process connection: Tri-Clamp DN 1 1/2"
Accuracy: 0.5% of span
Electrical connection: 4-pin L-plug DIN EN 175301-803, IP65
Certificates: quality certificates
Power supply: 10 ... 30 V DC
Pin assignment: UB=1, 0V=2
Made in Germany on label

© 2023 - WIKA Instruments s.a.r.l.

Date: 11/04/2023

WIKA standard - specification according to data sheet
System fill fluid: KN 77 Synthetic oil
Import documentation CIS-States: without
Test report 2.2 per EN 10204
Certificate Language: English and German
Certificate for: pressure transmitter
Formal certificate: Manufactured according to state-of-the-art
Inspection certificate 3.1 per EN 10204
Certificate type: Inspection certificate acc. to DIN EN 10204 3.1
Certificate Language: English and German
Certificate for: pressure transmitter
Accuracy: Calibration values listed
Material certificate: Wetted parts material (metal contents)

Label: WIKA standard without / with Tag-number
language of the label: English

© 2023 - WIKA Instruments s.a.r.l.