PRODUCT-DETAILS

# XT2V 160 Ekip LSI In=100A 3p F F

XT2V 160 Ekip LSI In=100A 3p F F



## General Information

| | |
|---|---|
| Extended Product Type | XT2V 160 Ekip LSI In=100A 3p F F |
| Product ID | 1SDA067984R1 |
| EAN | 8015644018801 |
| Catalog Description | XT2V 160 Ekip LSI In=100A 3p F F |
| Long Description | C.BREAKER TMAX XT2V 160 FIXED THREE-POLE WITH FRONT TERMINALS AND SOLID-STATE RELEASE IN AC EKIP-LSI R 100 A |

## Ordering

| | |
|---|---|
| EAN | 8015644018801 |
| Minimum Order Quantity | 1 piece |
| Customs Tariff Number | 85362090 |

## Dimensions

| | |
|---|---|
| Product Net Width | 90 mm |
| Product Net Height | 130 mm |
| Product Net Depth / Length | 82.5 mm |
| Product Net Weight | 1.12 kg |

## Container Information

| | |
|---|---|
| Package Level 1 Units | 1 piece |
| Package Level 1 Width | 130 mm |
| Package Level 1 Height | 208 mm |
| Package Level 1 Depth / Length | 145 mm |
| Package Level 1 Gross Weight | 1.22 kg |
| Package Level 1 EAN | 8015644018801 |

## Environmental

| | |
|---|---|
| RoHS Status | Following EU Directive 2011/65/EU and Amendment 2015/863 July 22, 2019 |

## Additional Information

| | |
|---|---|
| Circuit Breaker Type to be Associated | Power Distribution |
| Current Type | AC |
| Electrical Durability | 120 cycles per hour<br>8000 cycle |
| Mechanical Durability | Nr. Operations 240 cycles per hour<br>Nr. Operations 25000 cycle |
| Number of Poles | 3 |
| Opening Time | CB with SOR 15 ms<br>CB with UVR 15 ms |
| Order Multiple | 1 piece |
| Product Main Type | SACE Tmax XT |
| Product Name | Moulded Case Circuit Breaker |
| Product Type | CB |
| Rated Current ($I_n$) | 100 A |
| Rated Frequency (f) | 50 / 60 Hz |
| Rated Voltage ($U_r$) | 690 V |
| Rated Impulse Withstand Voltage ($U_{imp}$) | 8 kV |
| Rated Insulation Voltage ($U_i$) | 1000 V |
| Rated Operational Voltage | 690 V AC |
| Rated Service Short-Circuit Breaking Capacity ($I_{cs}$) | (220 V AC) 200 kA<br>(230 V AC) 200 kA<br>(240 V AC) 200 kA<br>(380 V AC) 150 kA<br>(415 V AC) 150 kA<br>(440 V AC) 150 kA<br>(500 V AC) 70 kA<br>(525 V AC) 50 kA<br>(690 V AC) 15 kA |
| Rated Ultimate Short-Circuit Breaking Capacity ($I_{cu}$) | (220 V AC) 200 kA<br>(230 V AC) 200 kA<br>(240 V AC) 200 kA<br>(380 V AC) 150 kA<br>(415 V AC) 150 kA<br>(440 V AC) 150 kA<br>(500 V AC) 70 kA<br>(525 V AC) 50 kA<br>(690 V AC) 20 kA |
| Rated Uninterrupted Current ($I_u$) | 160 A |
| Release | Ekip LSI |
| Release Type | EL |
| Short-Circuit | V |

| | |
|---|---|
| Performance Level | |
| Standards | IEC |
| Sub-type | XT2 |
| Terminal Connection Type | Fixed Circuit-Breakers |
| Version | F |

## Certificates and Declarations (Document Number)

| | |
|---|---|
| Data Sheet, Technical Information | 1SDC210100D0206<br>1SDC210099D0206 |
| Declaration of Conformity - CE | 9AKK106713A5901 |
| Environmental Information | 1SDL000190R0001 |
| GL Certificate | 1SDL000163R0093 |
| Instructions and Manuals | 1SDH000721R0001<br>1SDH000721R0506 |
| LR Certificate | 1SDL000163R0100 |

## Classifications

| | |
|---|---|
| ETIM 4 | EC000228 - Power circuit-breaker for trafo/generator/installation prot. |
| ETIM 5 | EC000228 - Power circuit-breaker for trafo/generator/installation prot. |
| ETIM 6 | EC000228 - Power circuit-breaker for trafo/generator/installation prot. |
| ETIM 7 | EC000228 - Power circuit-breaker for trafo/generator/installation protection |
| Object Classification Code | Q |
| UNSPSC | 39120000 |
| WEEE Category | 5. Small Equipment (No External Dimension More Than 50 cm) |

## Categories

Low Voltage Products and Systems → Circuit Breakers → Moulded Case Circuit Breakers → Tmax XT



