Date: 23/03/2026

IS-3 Standard ; 0 ... 16 bar; 4 ... 20 mA, 2-wire

IS-3 Standard ; 0 ... 16 bar; 4 ... 20 mA, 2-wire

Item number: 14818011

Quantity: 1 pcs.

Order code: IS-3-0-2111-1ZZ-BBKNBZZ-GTA3ZZZ-UAAZ
5W101AIS3ZZSF2ASQOGSI3
CERT22-EG1P-AA- - - - - - - - - - - I3

Overview: IS-3 Standard ; 0 ... 16 bar; 4 ... 20 mA, 2-wire
@ 10 ... 30 V DC
Accuracy: 0.5% of span
1/4 NPT
Sealing: without
Wetted parts: stainless steel
Adjustability: Zero/span adjustable
angular connector acc. to DIN EN 175301-803 A PG9
Cable material: without
Cable length: without
Pin assignment: U+=1, U-=2
permitted media temperature: -20...+80°C
Approvals: ATEX/IECEx
II 1/2G Ex ia IIC T4/T5/T6 Ga/Gb
Additional certifications: without
Special features: without
Test protocol: without test protocol
Additional ordering information: Without
Specifications according to data sheet: PE 81.58

Test report 2.2 per EN 10204
Certificate Language: English and German
Certificate for: pressure transmitter
Formal certificate: Manufactured according to state-of-the-art

Details: IS-3 Standard ; 0 ... 16 bar; 4 ... 20 mA, 2-wire
@ 10 ... 30 V DC
Accuracy: 0.5% of span
1/4 NPT
Sealing: without
Wetted parts: stainless steel
Adjustability: Zero/span adjustable
angular connector acc. to DIN EN 175301-803 A PG9
Cable material: without
Cable length: without

© 2026 - WIKA Instruments s.a.r.l.

Pin assignment: U+=1, U-=2
permitted media temperature: -20...+80°C
Approvals: ATEX/IECEx
II 1/2G Ex ia IIC T4/T5/T6 Ga/Gb
Additional certifications: without
Special features: without
Test protocol: without test protocol
Additional ordering information: Without
Specifications according to data sheet: PE 81.58

Test report 2.2 per EN 10204
Certificate Language: English and German
Certificate for: pressure transmitter
Formal certificate: Manufactured according to state-of-the-art

© 2026 - WIKA Instruments s.a.r.l.