Date: 22/04/2024

PCS2MB 20 … 100 bar 1/4 NPT-F, 1/2 -14 NPT-F

Compact Pressure Switch

Item number: 48771752

Quantity: 1 pcs.

Order code: PCS2MB-BAHB-1ASZZZZ1Z ZCKW
CERT22-EN2C-AA- - - - - - - -

Overview:
PCS2MB 20 … 100 bar 1/4 NPT-F, 1/2 -14 NPT-F
Compact Pressure Switch
PCS
switch enclosure: aluminium,copper-free
Measuring elements and wetted parts: Diaphragm Inconel + O-Ring FPM
Connection: Stainless steel AISI 316L
contact version: 1xSPDT, silver contact, hermetically sealed with argon gas
Setting range, working range, proof pressure: 20 … 100 bar, working range 0 … 100 bar, proof pressure 150 bar
Set point definition: Set Point not defined
Process connection: 1/4 NPT-F
Electrical connection: 1/2 -14 NPT-F
standard direct or wall mounting, fixing bore on the case

Ingress Protection: IP66
Brand: WIKA Instruments Italia
Specifications according to data sheet: PV 33.30
Repeatability of set point: ≤ 1% of end of setting range

Test report acc. to EN 10204 2.2
Test certificate acc. to EN 10204 2.2
Certificate Language: English
Formal certificate: Manufactured according to state-of-the-art

Details:
Compact Pressure Switch
Model PCS
Specifications according to data sheet: PV 33.30
Repeatability of set point: ≤ 1% of end of setting range
switch enclosure: aluminium,copper-free
Measuring elements and wetted parts: Diaphragm Inconel + O-Ring FPM
1xSPDT, silver contact, hermetically sealed with argon gas
20 … 100 bar, working range 0 … 100 bar, proof pressure 150 bar
Set Point not defined
Process connection: 1/4 NPT-F
Electrical connection: 1/2 -14 NPT-F
standard direct or wall mounting, fixing bore on the case
Approvals / Certificates: without

© 2024 - WIKA Instruments s.a.r.l.

Switch standard: without
Certificates: quality certificates
Brand: WIKA Instruments Italia
Ingress Protection: IP66
PCS2MB 20 … 100 bar
Test report acc. to EN 10204 2.2
Test certificate acc. to EN 10204 2.2
Certificate Language: English
Formal certificate: Manufactured according to state-of-the-art

© 2024 - WIKA Instruments s.a.r.l.