Specifications

Eaton 188187

Catalog Number: 188187

Eaton Moeller® series M30 Selector switch, RMQ-Titan, with thumb-grip, maintained, 3 positions, Front ring stainless steel M30I-FWRK3



General specifications

Product Name
Eaton Moeller® series M30 Selector switch

Catalog Number
188187

EAN
4015081858484

Product Length/Depth
36 mm

Product Height
47 mm

Product Width
46 mm

Product Weight
0.042 kg

Certifications
VDE 0660
IEC/EN 60947
CSA file No. 012528
CSA Class No.: 3211-03
DNV
UL File No.: E29184
GL
IEC/EN 60947-5
UL 508
CSA-C22.2 No. 14-05
CSA-C22.2 No. 94-91
CE marking
UL Category Control No.: NKCR
UL Listed
CSA certified

Powering Business Worldwide

Features & Functions

Bezel color

Stainless steel

Bezel material

Metal

Design

With thumb-grip

Flat front

Fitted with:

Plunger bridge for the middle contact

Front ring

Functions

Stay-put/spring-return function, can be changed with coding parts M22-XC-Y

General

Degree of protection

NEMA 4X, 13

Degree of protection (front side)

IP66

Lifespan, mechanical

100,000 Operations

Opening diameter

30 mm

Operating frequency

2000 Operations/h

Operating torque

0.3 Nm

Overvoltage category

III

Pollution degree

3

Product category

RMQ-Titan

Size

Front dimensions: Ø 36 mm

Switching angle

60 °

Type

Selector switch actuator

Ambient conditions, mechanical

Mounting position

As required

Shock resistance

15 g, Mechanical, According to IEC/EN 60068-2-27, Sinusoidal shock 11 ms

Mechanical, According to IEC/EN 60068-2-27

Climatic environmental conditions

Ambient operating temperature - min

-25 °C

Ambient operating temperature - max

70 °C

Ambient storage temperature - min

-40 °C

Ambient storage temperature - max

80 °C

Climatic proofing

Damp heat, cyclic, to IEC 60068-2-30

Damp heat, constant, to IEC 60068-2-78

Actuator

Actuator color

Black

Actuator function

Maintained

Switching function latching

Actuator type

Toggle

Number of switch positions

3

Communication

Connection to SmartWire-DT

With SWD-RMQ connections

Yes

Contacts

Force for positive opening - min

0 N

Design verification

Equipment heat dissipation, current-dependent Pvid

0 W

Heat dissipation capacity Pdiss

0 W

Heat dissipation per pole, current-dependent Pvid

0 W

Rated operational current for specified heat dissipation (In)

0 A

Static heat dissipation, non-current-dependent Pvs

0 W

10.2.2 Corrosion resistance

Meets the product standard's requirements.

10.2.3.1 Verification of thermal stability of enclosures

Meets the product standard's requirements.

10.2.3.2 Verification of resistance of insulating materials to normal heat

Meets the product standard's requirements.

10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects

Meets the product standard's requirements.

10.2.4 Resistance to ultra-violet (UV) radiation

Please enquire

10.2.5 Lifting

Does not apply, since the entire switchgear needs to be evaluated.

10.2.6 Mechanical impact

Does not apply, since the entire switchgear needs to be evaluated.

10.2.7 Inscriptions

Meets the product standard's requirements.

10.3 Degree of protection of assemblies

Does not apply, since the entire switchgear needs to be evaluated.

10.4 Clearances and creepage distances

Meets the product standard's requirements.

10.5 Protection against electric shock

Does not apply, since the entire switchgear needs to be evaluated.

10.6 Incorporation of switching devices and components

Does not apply, since the entire switchgear needs to be evaluated.

10.7 Internal electrical circuits and connections

Is the panel builder's responsibility.

10.8 Connections for external conductors

Is the panel builder's responsibility.

10.9.2 Power-frequency electric strength

Is the panel builder's responsibility.

10.9.3 Impulse withstand voltage

Is the panel builder's responsibility.

10.9.4 Testing of enclosures made of insulating material

Is the panel builder's responsibility.

10.10 Temperature rise

Not applicable.

10.11 Short-circuit rating

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 Electromagnetic compatibility

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.13 Mechanical function

The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Resources

Catalogs

eaton-rmq-titan-brochure-br047004en-en-us.pdf

eaton-pushbuttons-signal-towers-sensors-assortment-overview-catalog-ca047003en-en-us.pdf

Flip catalog - Product Range Catalog - Command and indication

Declarations of conformity

DA-DC-00004157.pdf

DA-DC-00004135.pdf

Drawings

eaton-operating-m30-changeover-switch-dimensions.eps

eaton-operating-m30-dimensions-005.eps

eaton-operating-m30-dimensions-004.eps

eaton-operating-m30-dimensions-006.eps

eaton-general-approval-m22-symbol.eps

eaton-general-m22-symbol.eps

eaton-operating-3d-drawing-008.eps

eCAD model

ETN.188187.edz

Installation instructions

eaton-operating-devices-m30-rmq-titan-flat-front-instruction-leaflet-il047019zu.pdf

Installation videos

RMQ Flat Design

mCAD model

DA-CS-wahltaste_knebel_flatfront

DA-CD-wahltaste_knebel_flatfront

Multimedia

easyE4 SmartWire-DT module with Remote Touch Display and RMQ multi color indicator

MCI MultiColor Light Indicator RMQ compact solution

RMQ small E-Stop emergency-stop button

MCI Multicolor Light Indicator M22 with SmartWire-DT

Sales notes

eaton-rmq-small-e-stop-flyer-fl047006en-en-us.pdf

eaton-rmq-flat-enclosure-flyer-fl047003en-en-us.pdf

eaton-rmq-mci-multi-color-light-indicator-flyer-fl047005en-en-us.pdf

eaton-control circuit-devices rmq-titan-fl144090en-en-us.pdf

Eaton Corporation plc
Eaton House
30 Pembroke Road
Dublin 4, Ireland
Eaton.com

© 2024 Eaton. All Rights Reserved.

Eaton is a registered trademark.

All other trademarks are property of their respective owners.

Eaton.com/socialmedia