*Date: 22/01/2024*

# IS-3 Standard ; 0 ... 2.5 bar; 4...20 mA, 2-wire

## IS-3 Standard ; 0 ... 2.5 bar; 4...20 mA, 2-wire

| | |
|---|---|
| Item number: | 46879357 |
| Quantity: | 1 pcs. |
| Order code: | IS-3-0-2111-1ZZ-BBFHDLZ-GTA3ZZZ-UAZZ<br>5W101AIS3ZZSF2ASQOGSI3 |
| Overview: | IS-3 Standard ; 0 ... 2.5 bar; 4...20 mA, 2-wire<br>@ 10 ... 30 V DC<br>Accuracy: 0.5% of span<br>G 1/4 A DIN EN ISO 1179-2<br>Sealing: FPM/FKM<br>Wetted parts: stainless steel<br>Adjustability: Zero/span adjustable<br>angular connector acc. to DIN EN 175301-803 A PG9<br>Cable material: without<br>Cable length: without<br>U+=1, U-=2<br>permitted media temperature: -20...+80°C<br>Approvals: ATEX/IECEx<br>II 1/2G Ex ia IIC T4/T5/T6 Ga/Gb<br>Additional certifications: without<br>Special features: without<br>Test protocol: without test protocol<br>Additional ordering information: without<br>Specifications according to data sheet: PE 81.58 |
| Details: | IS-3 Standard ; 0 ... 2.5 bar; 4...20 mA, 2-wire<br>@ 10 ... 30 V DC<br>Accuracy: 0.5% of span<br>G 1/4 A DIN EN ISO 1179-2<br>Sealing: FPM/FKM<br>Wetted parts: stainless steel<br>Adjustability: Zero/span adjustable<br>angular connector acc. to DIN EN 175301-803 A PG9<br>Cable material: without<br>Cable length: without<br>U+=1, U-=2<br>permitted media temperature: -20...+80°C<br>Approvals: ATEX/IECEx<br>II 1/2G Ex ia IIC T4/T5/T6 Ga/Gb<br>Additional certifications: without<br>Special features: without<br>Test protocol: without test protocol<br>Additional ordering information: without |

*© 2024 - WIKA Instruments s.a.r.l.*

*Date: 22/01/2024*

Specifications according to data sheet: PE 81.58

*© 2024 - WIKA Instruments s.a.r.l.*